


GOVERNMENT OF WESTBENGAL  
DEPARTMENT OF PUBLIC HEALTH ENGINEERING  
NEW SECRETARIAT BUILDINGS (7<sup>th</sup> floor), KOLKATA – 700001



Memo no: PHE / IV/ 1760 IO - 9/16 (Part -II)

Dated, Kolkata the 10.07.2017

ORDER

The undersigned is directed to say that the Govt. in PHE Department has hereby taken the following measures to ensure uninterrupted supply of desired quality and quantity of drinking water to the beneficiaries in rural part of West Bengal which are as follows :-

1. Residual chlorine content in the water immediately after the point of injection of chlorine near low lift or high lift pump house to be tested by the pump operators, working under the Mechanical wing of this Department and similarly residual chlorine content of atleast 3 delivery points to be tested by valve operator / cycle messengers working under Civil wing of this Department.
2. In case of PWSS (Direct pumping schemes), Pump operators have to test the residual chlorine content in the delivery points (SSP and at consumers end).
3. The chlorine doze to be controlled by the pump operators, depending upon the results of the residual chlorine content in the furthest delivery point of the distribution system in consultation with the concerned engineers of Civil and Mechanical wing of this Department.
4. All the analysed data of residual chlorine content to be uploaded in the PHED dashboard through mobile application.
5. The agencies entrusted for O&M of PWSS have to provide chlorine kit and smart phone to the pump operators / valve operators / cycle messengers at their own cost.
6. Necessary training in this respect to be provided to the agencies, pump operators / valve operators / cycle messengers for ensuring supply of safe water to the beneficiaries.
7. Necessary modification in the tender clauses and schedules to be made mandatory in the upcoming tenders for O&M of pump and distribution system of PWSS by both Civil and Mechanical wing of this Department.
8. Payment should be made to the agencies strictly on the basis of uninterrupted supply of desired quantity and quality of water to the beneficiaries.

All concerned are requested to strictly comply with the above mentioned instruction.

OSD & Ex Officio Special Secretary

Memo no: PHE / IV/ 1760 IO - 9/16 (Part -II)/1(10)

Dated, Kolkata the 10.07.2017

Copy forwarded for information to:-

1. The PA to the Additional Chief Secretary, PHE Department, Govt. of West Bengal.
2. The OSD & E-IN-C. PHE. Department, Govt. of West Bengal.
3. The Chief Engineer (Head Quarters), PHE Directorate, Govt. of West Bengal.
4. The Chief Engineer, Planning & WQM, PHE Directorate, Govt. of West Bengal.
5. The Chief Engineer, Western Zone, PHE Directorate, Govt. of West Bengal.
6. The Chief Engineer (M/E), Southern Zone, PHE Directorate, Govt. of West Bengal.
7. The Chief Engineer (M/E), Northern Zone, PHE Directorate, Govt. of West Bengal.
8. The Chief Engineer (Civil), Northern Zone, PHE Directorate, Govt. of West Bengal.
9. The Project Director, PMU, WBPWSP, PHE Directorate, Govt. of West Bengal.
10. The Director, WSSO, PHE Department, Govt. of West Bengal.

OSD & Ex Officio Special Secretary


Memo No. 8586-658

79/J/2011

Dated. 13-7-17

Copy forwarded for information & strict compliance to:

1. The Superintending Engineer, \_\_\_\_\_ Circle, PHE Dte.
2. The Executive Engineer, \_\_\_\_\_ Division, PHE Dte.



Chief Engineer (Head Quarters)  
PHE Directorate, Govt. of West Bengal