

Minutes of the DPR scrutinizing committee meeting held on 05/06/2020 at 3:00 PM at the Conference Room of Public Health Engineering Department, Government of West Bengal, New Secretariat Building, 7th Floor, 1, K.S. Roy Road, Kolkata- 700 001.

The list of officials present at the meeting is enclosed as **ANNEXURE-I**.

The meeting was chaired by Engineer-in-Chief, Public Health Engineering Department, Govt. of West Bengal. He welcomed all members present at the meeting and initiated discussion.

The following six (6) DPRs as listed on the agenda were scrutinized by the committee in the meeting.


<u>Sl. No.</u>	<u>DPR For</u>
1.	Water supply arrangements to different places like quarantine centers Hospital within Purulia District to combat Covid-19 pandemic situation under Purulia Division, PHE Dte. (Phase-I)
2.	Realignment of DI/UPVC pipelines at Zone-4 to facilitate construction and widening of bitumen/concrete road by Zilla Parisad under Budge Budge I of Surface Water Based Water Supply Scheme in the Arsenic affected areas of South 24 Parganas district
3.	Realignment of DI/UPVC pipelines at Zone-2, Zone-5 and Zone-6 to facilitate construction and widening of Concrete/Bitumen road by Zilla Parishad under Surface Water based Water Supply Scheme in Budge Budge-II for Arsenic affected areas of South 24 Parganas district.
4.	Coverage of quality affected habitations in Sonarpur (14 Nos), 7 Bhangar-I (8 nos) blocks with " Community Purification Plant (CPP)"
5.	Supply Delivery fabrication erection of 50 M3 IEP with allied works at head work site at zone 5 under improvement of Surface water based water supply scheme in the arsenic affected areas of South 24 Parganas
6.	Sinking of 16 nos. 100x40mm dia. 300 mtr. Deep tube well" for water supply arrangement of 8 nos. of villages under Budge budge-I block at zone no 5 of existing Surface water based water supply scheme in the Arsenic affected areas of South 24 Parganas district (Phase-I)

The DPR wise observations are given on separate sheets as **ANNEXURE II to VII**.

It was resolved in the meeting that:-

1. The observation of the committee against the DPRs mentioned under sl. 2 to sl. 5 are given under Annexure-II to V. The concerned Chief Engineers may be requested to resubmit the modified DPR based on the observation of the committee.
2. The DPR for sl no. 1 may be forwarded to the PHE Department for according administrative approval after enclosing the letter from the District Administration as detailed in Annexure-II
3. The DPR for sl no. 6 may be forwarded to PHE Department for according administrative approval (Ref : Annexure-VII)

As there was nothing left to discuss the meeting ended with vote of thanks to & from the chair.


Engineer-in-Chief
Public Health Engineering Department
&
Chairman - DPR Scrutinizing Committee

Memo No. 4812 / (1-2) MC / 1 /2020

Dated, Kolkata, the 12.06.2020

Copy forwarded for information to: -

1. Sr. PA to Principal Secretary, PHE Dcpartment, Govt. of West Bengal.
2. PA to Engineer-in-Chief, PHE Department, Govt. of West Bengal – Chairman of the committee.



(SANDEEP CHOUDHURY)

**Officer-on-Special Duty, Monitoring Cell
Public Health Engineering Directorate
&**


Member Convenor, DPR Scrutinizing Committee

Memo No. 4812 / (3-9) MC / 1 /2020

Dated, Kolkata, the 12.06.2020

Copy forwarded for information & necessary action to: -

3. Sri Animesh Bhattacharya, Chief Engineer, Headquarters, PHE Directorate - Co-opted Member
4. Md. Mahashin Ali Khan, Chief Engineer, Western Zone, PHE Directorate – Co-opted Member
5. Sri Hemanta Koley, Superintending Engineer, Planning Circle-I, PHE Directorate – Member.
6. Smt. Mousumi Datta, Executive Engineer-III, Investigation Unit, PHE Directorate – Member.
7. Sri Tanmoy Mondal, Executive Engineer (M/E), PIU, North 24 Parganas, WBDWSIP,PHE Dte. – Member
8. The Superintending Engineer-I, PMU, WBPWSP (Purulia) / S-24-Pgns W/S Circle, PHE Directorate.
9. The Executive Engineer, Purulia Division / South 24 Pgns W/S Division-I, PHE Directorate.



(SANDEEP CHOUDHURY)

**Officer-on-Special Duty, Monitoring Cell
Public Health Engineering Directorate
&**

Member Convenor, DPR Scrutinizing Committee

ANNEXURE-II


To the minutes of the DPR scrutinizing committee meeting held on 05/06/2020 at 3:00 PM at the Conference Room of Public Health Engineering Department, Government of West Bengal, New Secretariat Building, 7th Floor, 1, K.S. Roy Road, Kolkata- 700 001.

Sl. No.	DPR For	Observations
1.	Water supply arrangements to different places like quarantine centers Hospital within Purulia District to combat Covid-19 pandemic situation under Purulia Division, PHE Dte. (Phase-I)	i) Letter from district administration for providing drinking water at the Quarantine Centers was not found in the DPR. ii) Since other aspects of the DPR were found to be in order, the aforesaid letter may be enclosed and may be forwarded to PHE Department for according Administrative Approval.



Officer-on-Special Duty, Monitoring Cell
Public Health Engineering Directorate
&

Member Convenor - DPR Scrutinizing Committee



Superintending Engineer, Planning Circle-I
Public Health Engineering Directorate
&

Member - DPR Scrutinizing Committee



Engineer-in-Chief
Public Health Engineering Department
&
Chairman - DPR Scrutinizing Committee

ANNEXURE-III

To the minutes of the DPR scrutinizing committee meeting held on 05/06/2020 at 3:00 PM at the Conference Room of Public Health Engineering Department, Government of West Bengal, New Secretariat Building, 7th Floor, 1, K.S. Roy Road, Kolkata- 700 001.

Sl. No.	DPR For	Observations
2.	Realignment of DI/UPVC pipelines at Zone-4 to facilitate construction and widening of bitumen/concrete road by Zilla Parisad under Budge Budge I of Surface Water Based Water Supply Scheme in the Arsenic affected areas of South 24 Parganas district	i) Photocopies of approved rates of the Superintending Engineer, S-24-Pgns W/S Circle for item no. 8, 10 & 11 and rate analysis of item no. 16 are to be enclosed. ii) Year wise funding patterns are to be given. iii) The item of street stand post should be replaced by FHTC as per JJM Guideline.



Officer-on-Special Duty, Monitoring Cell
Public Health Engineering Directorate

&


Member Convenor - DPR Scrutinizing Committee



Superintending Engineer, Planning Circle-I
Public Health Engineering Directorate

&

Member - DPR Scrutinizing Committee




Engineer-in-Chief
Public Health Engineering Department
&
Chairman - DPR Scrutinizing Committee

ANNEXURE-IV

To the minutes of the DPR scrutinizing committee meeting held on 05/06/2020 at 3:00 PM at the Conference Room of Public Health Engineering Department, Government of West Bengal, New Secretariat Building, 7th Floor, 1, K.S. Roy Road, Kolkata- 700 001.

Sl. No.	DPR For	Observations
3.	Realignment of DI/UPVC pipelines at Zone-2, Zone-5 and Zone-6 to facilitate construction and widening of Concrete/Bitumen road by Zilla Parishad under Surface Water based Water Supply Scheme in Budge Budge-II for Arsenic affected areas of South 24 Parganas district.	<p>i) Photocopies of approved rates of the Superintending Engineer, S-24-Pgns W/S Circle for item no. 8, 10 & 11 and rate analysis of item no. 16 are to be enclosed.</p> <p>ii) Year wise funding patterns are to be given.</p> <p>iii) The item of street stand post should be replaced by FHTC as per JJM Guideline.</p>



**Officer-on-Special Duty, Monitoring Cell
Public Health Engineering Directorate
&**

Member Convenor - DPR Scrutinizing Committee



**Superintending Engineer, Planning Circle-I
Public Health Engineering Directorate
&**

Member - DPR Scrutinizing Committee



**Engineer-in-Chief
Public Health Engineering Department
&
Chairman - DPR Scrutinizing Committee**

ANNEXURE-V

To the minutes of the DPR scrutinizing committee meeting held on 05/06/2020 at 3:00 PM at the Conference Room of Public Health Engineering Department, Government of West Bengal, New Secretariat Building, 7th Floor, 1, K.S. Roy Road, Kolkata- 700 001.

Sl. No.	DPR For	Observations
4	Coverage of quality affected habitations in Sonarpur (14 Nos), 7 Bhangar-I (8 nos) blocks with " Community Purification Plant (CPP)"	i) Sketch of the vessel for different model estimate as per approved CPP model should be given. ii) The Chief Engineer, Headquarters informed at the meeting that the site list needs to be changed for which already necessary action has been taken. The DPR should be revised accordingly .


**Officer-on-Special Duty, Monitoring Cell
Public Health Engineering Directorate
&**

Member Convenor - DPR Scrutinizing Committee


**Superintending Engineer, Planning Circle-I
Public Health Engineering Directorate
&**

Member - DPR Scrutinizing Committee


**Engineer-in-Chief
Public Health Engineering Department
&
Chairman - DPR Scrutinizing Committee**

ANNEXURE-VI

To the minutes of the DPR scrutinizing committee meeting held on 05/06/2020 at 3:00 PM at the Conference Room of Public Health Engineering Department, Government of West Bengal, New Secretariat Building, 7th Floor, 1, K.S. Roy Road. Kolkata- 700 001.

Sl. No.	DPR For	Observations
5.	Supply Delivery fabrication erection of 50 M3 IEP with allied works at head work site at zone 5 under improvement of Surface water based water supply scheme in the arsenic affected areas of South 24 Parganas	<p>i) Justification of IEP installation by volumetric analysis, after blending of surface & ground water to be augmented.</p> <p>ii) Schematic diagram of pipeline, IEP & inter connection with existing OHR to be furnished.</p> <p>iii) Design calculation to be done on the basis of JJM guideline.</p> <p>iv) Yield of existing tube well to be considered for augmentation.</p> <p>v) In Annexure C (ii) item no. (3) & (4) to be deleted.</p> <p>vi) In Annexure C (III) DI pipe length to be calculated excluding special valves length. Quantity calculation for item no. 12 & 13. Remove item no. 17. Justification of item no. 18 & 19.</p> <p>vii) In Annexure C (iv) rate analysis required by obtaining market rate through quotation and specifically of pumping machinery specification to be mentioned with flow & head.</p>


**Officer-on-Special Duty, Monitoring Cell
Public Health Engineering Directorate**

Member Convenor - DPR Scrutinizing Committee


**Superintending Engineer, Planning Circle-I
Public Health Engineering Directorate**


Member - DPR Scrutinizing Committee


**Engineer-in-Chief
Public Health Engineering Department
&
Chairman - DPR Scrutinizing Committee**


ANNEXURE-VII

To the minutes of the DPR scrutinizing committee meeting held on 05/06/2020 at 3:00 PM at the Conference Room of Public Health Engineering Department, Government of West Bengal, New Secretariat Building, 7th Floor, 1, K.S. Roy Road, Kolkata- 700 001.

Sl. No.	DPR For	Observations
6.	Sinking of 16 nos. 100x40mm dia. 300 mtr. Deep tube well" for water supply arrangement of 8 nos. of villages under Budge budge-I block at zone no 5 of existing Surface water based water supply scheme in the Arsenic affected areas of South 24 Parganas district (Phase-I)	i) The DPR was found to be in order. Hence the same may be forwarded to PHE Department for according Administrative Approval.


Officer-on-Special Duty, Monitoring Cell
Public Health Engineering Directorate

&
Member Convenor - DPR Scrutinizing Committee


Superintending Engineer, Planning Circle-I
Public Health Engineering Directorate

&
Member - DPR Scrutinizing Committee


Engineer-in-Chief
Public Health Engineering Department
&
Chairman - DPR Scrutinizing Committee